



**TWO
RIVERS**
WISCONSIN

Special Event Inspection Checklist

Complete one checklist for general inspection

Fill out additional checklists for each vendor not in compliance

- Portable commercial Cooking Equipment Contract on File with FD
- Electrical Power Agreement on File with FD
- Extension cords of proper size/length and functional grounds at both ends
- One appliance per cord

- UL approved equipment
- Minimum distance of 10" from displays tents buildings and combustibles.
- Certificate of flame resistance from the manufacturer of tent on file with TRFD.
- Emergency shut down procedures permanently and conspicuously located
- Competent trained individual present (min 18 years of age)

- Required Fire extinguishers within proximity. 6 Liter K-Type for grease producing processes. 2- 10 lb ABC for LP fuel source.

Comments: _____

Event: _____

Date: _____

FD Inspector: _____

Signature

Print